Fort Carson, CO (719) 579 - 5811, Information (719) 579 - 2282 Every Office

ENERGY SAVINGS OPPORTUNITY SURVEY (MODIFIED)


Final Report:

FORT CARSON, COLORADO

Prepared for:

U.S. Army Engineer District, Omaha Corps of Engineers Omaha, Nebraska

Contract No. DACA45-84-C-0125



October, 1985

19971021 287

Volume 1

Forster-Morrell Engineering Associates, Inc. 2375 North Academy Boulevard, Suite #200 Colorado Springs, Colorado 80909

(303) 574-2127

PREFACE

This report is the final submission of Energy Savings Opportunities (Modified) at Fort Carson, Colorado. The report was prepared by Forster-Morrell Engineering Associates, Inc. of Colorado Springs, Colorado, and its consultants, Computer Applications and Engineering Resources, Inc. of Golden, Colorado. The project is under the direction of the Department of the Army, Omaha District Corps of Engineers in accordance with the requirements of Contract No. DACA45-84-C-0125. The intent of the study is to identify and develop cost effective energy conservation projects for Fort Carson.

DEPARTMENT OF THE ARMY

CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS
P.O. BOX 9005

CHAMPAIGN, ILLINOIS 61826-9005

REPLY-TO ATTENTION OF:

TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited. Distribution A. Approved for public release.

Marie Wakeffeld,

Librarian Engineering

TABLE OF CONTENTS Volume 1

	PAGE
EXECUTIVE SUMMARY	ES.1
SECTION 1: INTRODUCTION	
1.1 Authority and Scope1.2 Methods1.3 General Assumptions1.4 Master ECO List	1.1 1.2 1.3 1.3
SECTION 2: ENERGY CONSERVATION OPPORTUNITIES	2.1
2.1 Military Family Housing	2.1
2.1.1 ECO Application by MFH Unit 2.1.2 Non-applicable ECOs 2.1.3 Method of Analysis 2.1.4 Special Assumptions 2.1.5 Summary of Results	2.1 2.4 2.5 2.5 2.7
2.2 ECO Reevaluations	2.29
 2.2.1 Specific ECOs 2.2.2 Previous Energy Conservation Analysis 2.2.3 Method of Analysis 2.2.4 Special Assumptions 2.2.5 Summary of Results 	2.29 2.29 2.30 2.32 2.34
2.3 Annex A Buildings	2.39
 2.3.1 ECO Application by Building 2.3.2 Non-Applicable ECOs 2.3.3 Method of Analysis 2.3.4 Special Assumptions 2.3.5 Summary of Results 	2.39 2.44 2.49 2.50 2.51
2.4 Annex B Buildings	2.76
2.4.1 ECO Application by Building 2.4.2 Non-Applicable ECOs 2.4.3 Method of Analysis 2.4.4 Special Assumptions	2.76 2.83 2.89 2.90

SECTION 3: ECO PACKAGE ANALYSIS	3.1	
 3.1 Method of Analysis 3.2 Applicable ECOs Considered for Packaging 3.3 Results of Analysis - Temporary Buildings 3.4 Results of Analysis - Permanent Buildings 3.5 Results of Analysis - Temporary Reevaluation Buildings 3.6 Results of Analysis - Military Family Housing Buildings 	ngs ings	3.1 3.6 3.22 3.32 3.48 3.49
SECTION 4: QUALIFYING ECIP PROJECTS	4.1	
4.1 Potential Projects with Evaluation Summaries		4.1
4.1.1 Military Family Housing Projects 4.1.2 MCA O & M Projects - Permanent Buildings 4.1.3 MCA O & M Projects - Temporary Buildings		4.1 4.4 4.15
SECTION 5: QUALIFYING NON ECIP PROJECTS	5.1	
5.1 Potential Projects with Evaluation Summaries		5.1
SECTION 6: INFEASIBLE ECOs	6.1	
6.1 General6.2 Method of Analysis		6.1 6.1
SECTION 7: TRAINING REQUIREMENTS	7.1	
7.1 ECO Training Requirements7.2 Additional Training Needs7.3 Available Programs		7.1 7.2 7.2
SECTION 8: EQUIPMENT REPLACEMENT STUDY	8.1	

TABLE OF CONTENTS

Volume 2

EXECUTIVE SUMMARY	Page No.
SECTION 1: INTRODUCTION	
1.1 Objectives 1.2 Authority and Scope 1.3 General Requirements 1.4 Major Assumptions and Data Sources 1.5 Review of Previous Work	1.1 1.1 1.2 1.3 1.4
SECTION 2: BUILDINGS AND SYSTEMS DATA	
 2.1 Building Lists by Groups 2.2 General Condition 2.3 Facilities Operation and Maintenance 2.4 Energy Resources and Consumption 2.5 Existing Data Transmission Media 	2.1 2.8 2.8 2.8 2.9
SECTION 3: ENERGY MONITORING AND	
CONTROL SYSTEMS APPLICATIONS 3.1 EMCS Monitor & Control Functions 3.2 Applications to Buildings	3.1 3.2
SECTION 4: EMCS ARCHITECTURE & COST ESTIMATES	
 4.1 General Characteristics 4.2 Master Control Room 4.3 Data Transmission Media 4.4 Distributed Monitor and Control Equipment 4.5 The Data Environment 4.6 EMCS Operation and Maintenance 4.7 Cost Estimates 	4.1 4.1 4.5 4.5 4.6 4.6 4.26
SECTION_5: ANALYSIS	
5.1 Methodology 5.2 FACE Program Energy Constants 5.3 Results of Analysis	5.1 5.2 5.5
SECTION 6: SUMMARY OF THE EMCS STUDY RESULTS	
6.1 Building, Point and Function Summary 6.2 EMCS Performance Summary	6.1 6.1

SECTION 7: LOW COST ALTERNATIVE STUDY	Page No.
 7.1 Low Cost Alternative System Definiti 7.2 Method of Analysis 7.3 Cost Estimates 7.4 Results of Analysis by Building 7.5 Final LCA Results 	on 7.1 7.1 7.1 7.9 7.9
SECTION 8: EMCS AND LCA RESULTS FOR REIMBURS UTILITY BUILDINGS	ABLE
 8.1 List of Reimbursable Utility Buildin 8.2 Method of Analysis 8.3 EMCS System 8.4 LCA System 8.5 0 & M Repair Cost Estimate 	8.1 8.1 8.1 8.6 8.10
SECTION 9: CONCLUSIONS AND RECOMMENDATIONS	
9.1 Energy Monitoring and Control System9.2 Low Cost Alternative	9.1 9.1

APPENDICES

VOLUME 1, BOOK 1

- A. Scope of Work
- B. Minutes of Prenegotiation Meeting
- C. Certification of Temporary Buildings
- D. Bin Chart Energy Analysis Program Description BCEP
- E. Hourly Energy Analysis Program Description BLAST/QUIKEE
- F. EMCS Energy Analysis Program Description FACE
- G. Fort Carson Utility Rates, Energy Price Equivalents, and Abbreviations
- H. Engineering Economics (Present Worth Factors)
- I. Reevaluation Buildings Original Study Backup Data

VOLUME_1, BOOK 2

- J. Field Survey Forms Primary Buildings
- K. BCEP BIN Chart Data for Colorado Springs
- Computer Simulation Input and Output Summaries (Through Building 1951)

VOLUME 1, BOOK 3

- L. Computer Simulation Input and Output Summaries (From Building 1957)
- M. Building Similarity Ratio, Definitions and Program Description PESEP
- N. Individual ECO Evaluations, Cost Estimates and ECIP Evaluations

VOLUME 1, BOOK 4

- 0. Similarity Extension Evaluations
- P. Primary and Similar Building ECO Package Cost Estimates
- Q. EMCS Building Controls Survey Forms
- R. Fort Carson Delivered Hot Water and Steam Efficiencies (Main Plants)

VOLUME 1, BOOK 4 (Continued)

- S. Fort Carson Individual Building Heating Plant Efficiencies
- T. Derivation of Cost Adjustment Factors, Fort Carson
- U. Field Survey Forms Similar Buildings

VOLUME 1, BOOK 5

V. Program Documents

LIST OF FIGURES

VOLUME 1

Figure No.	Title	Page No.
ES-1	EMCS Schematic Diagram	ES.6

LIST OF TABLES

VOLUME I

TABLE No.	I I I L L PA	IGE NO.
ES.1	SUMMARY OF RECOMMENDED PROJECTS	ES.2
ES.2	MASTER ECO LIST	ES.4
ES.3	PROJECT SUMMARY - DISCRETE PORTION RESULTS MFH PACKAGE #8 - ECIP PROJECT	ES.9
ES.4	PROJECT SUMMARY - DISCRETE PORTION RESULTS MFH PACKAGE #9 - ECIP PROJECT	ES.9
ES.5	PROJECT SUMMARY - DISCRETE PORTION RESULTS PERMANENT BUILDINGS PACKAGE #1 - ECIP PROJECT	ES.10
ES.6	PROJECT SUMMARY - DISCRETE PORTION RESULTS PERMANENT BUILDINGS PACKAGE #4 - ECIP PROJECT	ES.10
ES.7	PROJECT SUMMARY - DISCRETE PORTION RESULTS PERMANENT BUILDINGS PACKAGE #5 - ECIP PROJECT	ES.11
ES.8	PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3 #6, #7 - ECIP PROJECT	ES.11
ES.9	PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - QRIP PROJECT - NORTH AREA	ES.13
ES.10	PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - QRIP PROJECT - MID AREA	ES.13
ES.11	PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - QRIP PROJECT - SOUTH AREA	ES.14
ES.12	PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - PECIP PROJECT	ES.15
1.4.1	MASTER ECO LIST	1.4
2.1.1	PRIMARY AND SIMILAR BUILDING COUNT	2.1
2.1.2	ECO APPLICABILITY BY BUILDING FOR MFH UNITS	2.3
2.1.3	MFH BASELINE ANNUAL RAW SOURCE ENERGY CONSUMPTION	2.8

2.1.4	MFH ECO #1: WALL AND PERIMETER INSULATION ECONOMIC ANALYSIS RESULTS	2.9
2.1.5	MFH ECO #3: INFILTRATION REDUCTION ECONOMIC ANALYSIS RESULTS	2.10
2.1.6	MFH ECO #9: DHW HEATER REPLACEMENT ECONOMIC ANALYSIS RESULTS	2.11
2.1.7	MFH ECO #10: HIGH EFFICIENCY LIGHTS ECONOMIC ANALYSIS RESULTS	2.12
2.1.8	MFH ECO #14: NEW SETBACK T'STATS ECONOMIC ANALYSIS RESULTS	2.13
2.1.9	MFH ECO #34: MFH FURNACE REPLACEMENT ECONOMIC ANALYSIS RESULTS	2.14
2.1.10	MFH ECO #35: EXTERIOR LIGHT PHOTOCELL ECONOMIC ANALYSIS RESULTS	2.15
2.1.11	ECO RESULTS SUMMARY FOR ALL QUALIFYING MFH UNITS	2.16
2.1.12	FORT CARSON MFH BUILDING SIMILARITY LIST	2.17
2.2.1	REEVALUATION BASELINE ENERGY CONSUMPTION	2.34
2.2.2	REEVALUATION ECO #1: ATTIC INSULATION ECONOMIC ANALYSIS RESULTS	2.35
2.2.3	REEVALUATION ECO #2: DOUBLE GLAZING ECONOMIC ANALYSIS RESULTS	2.36
2.2.4	REEVALUATION ECO #19: RADIATOR STEAM CONTROL VALVES ECONOMIC ANALYSIS RESULTS	2.37
2.2.5	REEVALUATION ECO #34: DUCT DAMPER UPDATED ECONOMIC ANALYSIS RESULTS	2.38
2.3.1	FORT CARSON ANNEX A BUILDING SIMILARITY LIST	2.39
2.3.2	ECO APPLICABILITY BY BUILDING - ANNEX A	2.43
2.3.3	ANNEX A ANNUAL BASELINE RAW SOURCE ENERGY CONSUMPTION	2.52
2.3.4	ANNEX A ECO #1: INSULATION	2.55
2.3.5	ANNEX A ECO #2: STORM WINDOWS	2.56
2.3.6	ANNEX A ECO #3: WEATHERSTRIPPING	2.57
2.3.7	ANNEX A ECO #4: INSULATED PANELS	2.58

2.3.8	ANNEX A ECO	#5: VESTIBULES	2.59
2.3.9	ANNEX A ECO	#6: AIR CURTAINS	2.60
2.3.10	ANNEX A ECO	#9: MODIFY DHW HEATERS	2.61
2.3.11	ANNEX A ECO	#12: EFFICIENT LIGHTING	2.62
2.3.12	ANNEX A ECO	#13: HIGH EFFICIENCY MOTORS	2.63
2.3.13	ANNEX A ECO	#14: NIGHT SETBACK T'STATS	2.64
2.3.14	ANNEX A ECO	#15: INFRARED HEATERS	2.65
2.3.15	ANNEX A ECO	#16: ECONOMIZER CYCLE	2.66
2.3.16	ANNEX A ECO	#19: RADIATOR CONTROLS	2.67
2.3.17	ANNEX A ECO	#21: HEAT RECOVERY FROM HOT REFRIGERANT GAS	2.68
2.3.18	ANNEX A ECO	#23: DESTRATIFICATION FANS	2.69
2.3.19	ANNEX A ECO	#24: TIME CLOCKS	2.70
2.3.20	ANNEX A ECO	#27: INSULATE STEAM LINES	2.71
2.3.21	ANNEX A ECO	#31: REVISE HVAC CONTROLS	2.72
2.3.22	ANNEX A ECO	#32: WASTE HEAT RECOVERY	2.73
2.3.23	ANNEX A ECO	#34: HVAC INITIATIVES	2.74
2.3.24	ANNEX A ECO	#35: EXTERIOR LIGHTING CONTROLS	2.75
2.4.1	FORT CARSON SIMILARITY	ANNEX B BUILDING LIST	2.76
2.4.2	ECO APPLICA BUILDINGS	BILITY by BUILDING for ANNEX B	2.81
2.4.3	ANNEX B ANN ENERGY CONS	UAL BASELINE RAW SOURCE UMPTION	2.92
2.4.4	ANNEX B ECO	#1: INSULATION	2.93
2.4.5	ANNEX B ECO	#2: STORM WINDOWS OR DOUBLE GLAZING	2.94
2.4.6	ANNEX B ECO	#3: WEATHERSTRIPPING and CAULKING	2.96
2.4.7	ANNEX B ECO	#4: INSULATED PANELS	2.97

2.4.8	ANNEX B ECO #5: VESTIBULES	2.98
2.4.9	ANNEX B ECO #6: AIR CURTAINS	2.99
2.4.10	ANNEX B ECO #9: MODIFY DHW	2.100
2.4.11	ANNEX B ECO #12: EFFICIENT LIGHTING	2.101
2.4.12	ANNEX B ECO #13: HI-EFFICIENCY MOTOR REPLACEMENT	2.102
2.4.13	ANNEX B ECO #14: SETUP/BACK T'STATS	2.103
2.4.14	ANNEX B ECO #15: INFRARED HEATERS	2.104
2.4.15	ANNEX B ECO #16: ECONOMIZER CYCLE	2.105
2.4.16	ANNEX B ECO #19: RADIATOR CONTROLS	2.106
2.4.17	ANNEX B ECO #23: PREVENT AIR STRATIFICATION	2.107
2.4.18	ANNEX B ECO #24: INSTALL TIME CLOCKS	2.108
2.4.19	ANNEX B ECO #31: REVISE OR REPAIR HVAC CONTROLS	2.109
2.4.20	ANNEX B ECO #34: HVAC INITIATIVES (BUILDINGS with SEPARATE BOILERS)	2.110
2.4.21	ANNEX B ECO #35: EXTERIOR LIGHTING CONTROLS	2.111
3.1	PACKAGE #1 PERMANENT BUILDINGS - ARCHITECTURAL ECOs	3.6
3.2	PACKAGE #2 TEMPORARY BUILDINGS - ARCHITECTURAL ECOs	3.9
3.3	PACKAGE #3 TEMPORARY BUILDINGS - HVAC (BOILER/FURNACE and ELECTRICAL)	3.12
3.4	PACKAGE #4 PERMANENT BUILDINGS - HVAC (CONTROLS)	3.15
3.5	PACKAGE #5 PERMANENT BUILDINGS - HVAC (PLANT and ELECTRICAL)	3.18
3.6	PACKAGE #6 TEMPORARY REEVALUATION BUILDINGS - ARCHITECTURAL ECOs	3.20
3.7	PACKAGE #7 TEMPORARY REEVALUATION BUILDINGS - HVAC (CONTROLS)	3.20
3.8	PACKAGE #8 MILITARY FAMILY HOUSING BUILDINGS - ARCHITECTURAL ECOs	3.21

3.9	PACKAGE #9 MILITARY FAMILY HOUSING BUILDINGS - MODIFY DHW	3.21
3.10	PACKAGE #2 SUMMARY OF RESULTS	3.22
3.11	PACKAGE #3 SUMMARY OF RESULTS	3.23
3.12	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-106	3.24
3.13	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-203	3.24
3.14	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-211	3.25
3.15	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-304	3.27
3.16	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-307	3.27
3.17	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-310	3.27
3.18	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-500	3.28
3.19	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-806	3.28
3.20	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-1302	3.28
3.21	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-1340	3.29
3.22	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-1405	3.29
3.23	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-1444	3.29
3.24	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-2200	3.30
3.25	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #T-2341	3.30
3.26	PACKAGE #1 SUMMARY OF RESULTS	3.32
3.27	PACKAGE #4 SUMMARY OF RESULTS	3.33
3.28	PACKAGE #5 SUMMARY OF RESULTS	3.34

3.29	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-633	3.35
	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-1007	3.35
3.31	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-1011	3.36
	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-1118	3.37
	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-1855	3.38
	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-1950	3.39
3.35	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-1951	3.39
3.36	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-1955	3.42
3.37	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-1957	3.43
	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-2350	3.44
3.39	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-2357	3.44
3.40	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #P-2359	3.45
3.41	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #S-6220	3.46
	SIMILAR BUILDING ECO PACKAGE EXTENSION RESULTS FOR PRIMARY BLDG #S-6230	3.47
	PACKAGE #6 TEMPORARY REEVALUATION BUILDINGS SUMMARY OF RESULTS	.48
	PACKAGE #7 TEMPORARY REEVALUATION BUILDINGS SUMMARY OF RESULTS	8.48
	PACKAGE #8 MILITARY FAMILY HOUSING SUMMARY OF RESULTS	3.49
	PACKAGE #9 MILITARY FAMILY HOUSING SUMMARY OF RESULTS	3.50

4.1.1	PROJECT SUMMARY - DISCRETE PORTION RESULTS MFH PACKAGE #8 - ECIP PROJECT	4.2
4.1.2	ECIP PROJECT DATA - MFH BUILDINGS - PACKAGE #8	4.2
4.1.3	PROJECT SUMMARY - DISCRETE PORTION RESULTS - MFH PACKAGE #9 - ECIP PROJECT	4.3
4.1.4	ECIP PROJECT DATA - MFH BUILDINGS - PACKAGE #9	4.3
4.1.5	PROJECT SUMMARY - DISCRETE PORTION RESULTS - PERMANENT BUILDINGS PACKAGE #1 - ECIP PROJECT	4.4
4.1.6	ECIP PROJECT DATA - PERMANENT BUILDINGS - PACKAGE #1	4.5
4.1.7	PROJECT SUMMARY - DISCRETE PORTION RESULTS - PERMANENT BUILDINGS PACKAGE #4 - ECIP PROJECT	4.8
4.1.8	ECIP PROJECT DATA - PERMANENT BUILDINGS - PACKAGE #4	4.8
4.1.9	PROJECT SUMMARY - DISCRETE PORTION RESULTS - PERMANENT BUILDINGS PACKAGE #5 - ECIP PROJECT	4.12
4.1.10	ECIP PROJECT DATA - PERMANENT BUILDINGS - PACKAGE #5	4.12
4.1.11	PROJECT SUMMARY - DISCRETE PORTION RESULTS - TEMPORARY BUILDINGS PACKAGES #2, #3, #6, #7 - ECIP PROJECT	4.16
4.1.12	ECIP PROJECT DATA - TEMPORARY BUILDINGS - PACKAGES #2, 3, 6, 7	4.16
5.1.1	PROJECT SUMARY - DISCRETE PORTION RESULTS - TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - QRIP PROJECT, NORTH AREA	5.2
5.1.2	QRIP PROJECT DATA - TEMPORARY BUILDINGS - PACKAGE #3, NORTH AREA	5.3
5.1.3	PROJECT SUMMARY - DISCRETE PORTION RESULTS - TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - QRIP PROJECT, MID AREA	5.4
5.1.4	QRIP PROJECT DATA - TEMPORARY BUILDINGS - PACKAGE #3, MID AREA	5.4
5.1.5	PROJECT SUMMARY - DISCRETE PORTION RESULTS - TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 -	5 5

5.1.6	QRIP PROJECT DATA - TEMPORARY BUILDINGS - PACKAGES #3, 7, SOUTH AREA	5.5
5.1.7	PROJECT SUMMARY - DISCRETE PORTION RESULTS - TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - PECIP PROJECT	5.7
5.1.8	PECIP PROJECT DATA - TEMPORARY BUILDINGS - PACKAGES #3, 7	5.7
6.1	MILITARY FAMILY HOUSING INFEASIBLE ECOs	6.2
6.2	TEMPORARY REEVALUATION BUILDINGS INFEASIBLE ECOs	6.3
6.3	TEMPORARY BUILDINGS INFEASIBLE ECOs	6.4
6.4	PERMANENT BUILDINGS INFEASIBLE ECOs	6.7
7.1	FORT CARSON TRAINING PROGRAM NEEDS	7.6

EXECUTIVE SUMMARY

Objective

The objective of the energy conservation study at Fort Carson is to determine the feasibility of Energy Conservation Opportunities (ECOs) as specified in the Scope of Work. The criteria for a qualifying ECO is a Savings-to-Investment Ratio (SIR) greater than or equal to 1 (SIR >= 1). ECOs are numbered, defined and listed in Table ES.2, on page ES-4.

Authority and Scope

The contractual authority for this specific study is contract No. DACA45-84-C-0125. The Scope of Work lists seven elements of work to be accomplished.

- (1) Review previous studies (by Burns and McDonnell).
- (2) Reevaluate selected projects (ECOs 1, 2, 19 and 34 as applied to eight temporary buildings).
- (3) Evaluate selected ECOs:
 - a. 14 primary and 536 similar Military Family Housing (MFH) buildings for a total of 1,827 housing units.
 - b. 29 primary and 63 similar temporary buildings.
 - c. 23 primary and 94 similar permanent buildings.
 - d. 13 primary and 166 similar permanent buildings to be evaluated for applicability for Energy Monitoring and Control System (EMCS) and Low Cost Alternatives (LCA).
- (4) Perform a limited site survey: survey the designated buildings for application of the ECOs in Table ES.2, acquire the data necessary to support the energy analysis, and identify the local loop controls that need repair or replacement in the 179 buildings to be evaluated for the EMCS.
- (5) Provide programming or implementation documentation for projects (ECIP, PECIP, QRIP) developed during this study.
- (6) Training and expendable equipment replacement: describe any training required in energy related areas of maintenance and operation, and describe expendable equipment that should be changed to a higher efficiency type at the next replacement.
- (7) Submittals, presentations and reviews: fully document the work with a comprehensive report.

Project_Summary

Eleven projects are recommended for funding at the Fort Carson installation. Seven ECIP, three QRIP and one PECIP funding projects indicate a combined annual energy cost savings of \$2,974,748. Total recommended FY 88 ECIP project costs equal \$16,279,000 while the QRIP and PECIP projects have a combined Jan. 1985 through July 1985 investment cost of \$538,758.

TABLE ES.1
SUMMARY OF RECOMMENDED PROJECTS

FUNDING PROGRAM & PKG #	BLDG. GROUP	ENERGY	NUAL SAVINGS BTU) (ELEC)	ANNUAL COST SAVINGS \$	ESTIMATED INVESTMENT COST \$ (1985)	SIR	SIMPLE PAYBACK
ECIP-5 ECIP-4 ECIP-8 ECIP-1 ECIP ECIP-9	PERM PERM MFH PERM TEMP MFH	60,053 133,018 37,790 56,214 31,685 14,847	8,351 2,683 12,412 0 249	288,032 587,212 201,262 247,596 144,702 67,530	1,580,705 2,231,098 2,155,725 2,572,861 810,284 713,506	3.71 3.27 1.87 1.79 1.58 1.58	5.4 4.3 10.2 12.8 5.8 7.5
ECIP	EMCS	248,002	37,538	1,097,081	3,879,384,	3.70	3.5
TOTAL EC	ΙP	581,609	61,233	2,633,415	13,943,563		
QRIP-N QRIP-M QRIP-S PECIP	TEMP TEMP TEMP TEMP	15,075 9,130 14,130 24,744	0 0 45 152	68,566 41,526 64,375 112,902	77,826 47,337 88,669 324,926	8.28 8.21 6.77 3.23	1.1 1.1 1.3 2.8
TOTAL NO	N-ECIP	63,079	197	287,369	538,758		

Method of Analysis

Extensive field surveys were conducted to determine the applicability of selected ECOs and contractor-defined ECOs, and to acquire the data to support calculations and analysis.

Computer programs (BLAST 3, QUIKEE or BCEP) were used to first model existing conditions and then to determine effects of each applicable ECO for the primary buildings; hand calculations were used when appropriate. An economic analysis was made for each ECO on each primary building to establish ECO qualification status under the current ECIP guidelines.

Coordination meetings resulted in selected ECIP, QRIP and PECIP projects consisting of grouped ECOs. The groups of ECOs were evaluated by computer on the primary buildings and the effectiveness of each individual ECO was established taking all overlapping effects into account. Projects were modified to include only qualifying ECOs, and the results were extended to the similar buildings.

The EMCS study methodology is somewhat different and involves the application of ECO #42 to 171 designated buildings. Eight of the 179 buildings listed in the Scope of Work are either not in use, or not conditioned. Each primary building was modelled with a computer program to obtain energy consumption for the existing conditions.

Each of the 171 buildings was surveyed and potential functions were identified. The energy savings were calculated program, Facilities Automation Controls computer which follows the method (FACE) developed Evaluation "Standardized EMCS Energy Savings Calculations" by Newcombe Boyd Architects and Engineers. The method was developed for the Naval Civil Engineering Laboratory in 1982 and has been approved by the Army Corps of Engineers. FACE uses a number of energy constants derived from energy consumption simulations of primary buildings. These constants were then modified for each similar building. An economic analysis of the cost effectiveness of each EMCS function for each mechanical system was made.

A Low Cost Alternative (LCA) study was accomplished to provide an alternative approach that produces most of the energy savings of the EMCS. The analytical procedure is the same as that used for the EMCS study. The LCA system provides all of the energy savings that the EMCS does with the single exception of electrical demand limiting. Essentially the LCA configuration employs the stand-alone, distributed control units of the EMCS without the master control room equipment and software, and without the extensive data transmission media of the EMCS.

TABLE ES.2 MASTER ECO LIST

Master List No.	ECO DESCRIPTION
1	Insulation (walls, ceilings, roofs, crawlspace,
	slabs)
2	Storm windows or double glazing
3 4	Weatherstripping and caulking
4	Insulated panels
5 6	Vestibules or revolving doors
6	Load dock seals/air curtains/strip doors
7	Reduction of glass area
8	*Replace kitchen light fixtures
9	Shutdown, modify or replace hw heaters
10	Reduce lighting levels
11 12	*Replace incandescent lighting
13	*Use more efficient lighting source High efficiency motor replacement
14	Night setback/setup thermostats
15	Infrared heaters (shops and warehouses)
16	Economizer cycles (dry bulb types)
17	Control hot water circulation pumps
18	FM radio controls
19	Radiator controls
20	Point-of-use hot water heaters
21	Heat reclaim from hot refrigerant gas
22	Reduce air flow
23	Prevent air stratification
24	Install time clocks
25	Chiller replacement
26	Replace absorption chiller
27	Insulate steam lines
28	Return condensate
29 30	Transformer over voltage
31	Transformer loading Revise or repair HVAC controls
32	Waste heat recovery
33	Add additional light switches
34	HVAC initiatives
35	Exterior lighting control (photocells)
36	Boiler oxygen trim controls
37	Revise boiler controls
38	Preheat domestic hot water
39	Heat pumps
4 U	High pressure sodium street lights
41	Electric outlet insulation
42	Energy Monitoring and Control System (EMCS)

^{*} ECO #8, 11 and 12 are combined in 12

Summary of EMCS_Results

Appropriated Fund (0 & M) Buildings:

161 non-reimbursable utilities buildings were analyzed for the application of a large EMCS system; 128 buildings qualified under the ECIP criteria. The reimbursable utilities buildings were analyzed separately and are shown below. Figure ES-1 is the EMCS schematic for the qualifying buildings. The system is recommended for ECIP funding in FY 1988. This project was analyzed from January through July 1985 and the programmed FY 88 cost is \$4,530,000.

The major features of the EMCS are summarized below.


Length No. of No. of No. of No. of			128 69,700 ft. 43 2 35 93 5,739
	electrical savings natural gas savings	(\$)	86,976
Annual Annual	maintenance cost electrical demand sa	(\$)	1,064,069 \$ 60,882 \$ 6,918
Total E	ual cost savings MCS investment cost payback period = 3 3.7	.5 years	\$1,097,081 \$3,879,384

The Project Development Brochure and DD 1391 are completed and submitted.

The performance of the EMCS depends in a major way on the working condition of the local loop control elements. The repair and maintenance of these controls is an ongoing job that must be completed for any system to function properly. Each building was surveyed for broken or damaged controls and actuators to provide a reasonable and probable cost of repair, calibration and adjustment on the EMCS buildings. The estimated repair work cost is established to be \$246,671 and should be included in the 0&M budget for FY 88.

Reimbursable Utilities Buildings:

Ten designated buildings were analyzed for connection to the large EMCS described above. The project to connect the buildings to the EMCS is not a candidate for ECIP funding since the utility costs are paid by the tenants. However, the analysis using the



ECIP criteria is included to aid Ft Carson in the event they wish to add these buildings to the large EMCS. This project was analyzed from January through July 1985. The results are summarized below.

Number of buildings	10	
Number of FIDs	2	
Number of MUX panels	8	
Length of DTM lines	2,940	feet
Number of DE points	568	
Annual electrical savings		MBTU/\$7,067
Annual natural gas savings	14,306	MBTU/\$60,908
Annual maintenance cost	\$ 8,997	
Net annual avoided cost	\$ 58,978	
Total Investment Cost	\$179,945	
Simple payback period	3.2	years
SIR	4.4	

It is recommended that this system be connected to the large EMCS for the 128 qualifying 0&M buildings.

Summary_of_LCA_Results

Appropriated Fund (0 & M) Buildings:

The 161 0&M buildings were analyzed for the application of the LCA. 126 buildings qualified under current ECIP criteria. The system is not recommended for implementation, as the loss in maintenance reporting capability and centralized alarm notification outweigh the \$910,733 investment cost savings over the EMCS. Major features and performance are summarized below.

Number of buildings	126	
Length of buried cable	27,110	feet
Number of line drivers	0	
Number of modems	0	
Number of FIDs	38	
Number of MUX panels	88	
Number of DE points	5,712	
Annual electrical savings	37,434	MBTU/\$88,614
Annual natural gas savings		MBTU/\$1,059,374
Annual maintenance cost	\$ 148,433	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
Net annual cost savings	\$ 851,103	
Total LCA investment cost	\$2,968,651	
Simple payback period		years
SIR	4.6	J 2 2 .
51K	4.6	

Reimbursable Utilities Buildings:

The 10 reimbursable utilities (RU) buildings were analyzed for avoided costs in connection with adding them onto the large LCA

for the 126 0&M buildings described above. Eight of the buildings show simple payback periods of less than 10 years. This project was analyzed from January through July 1985. The results for all 10 buildings are summarized below.

Number of buildings	10	
Number of FIDs to be purchased	3	
Number of MUX panels	6	
Length of DTM lines	1,440	feet
Number of DE points	568	
Annual electrical savings		MBTU/\$6,036
Annual natural gas savings	14,306	MBTU/\$60,908
Annual maintenance cost	\$ 8,694	
Net annual avoided cost	\$ 58,250	
Total Investment Cost	\$173,884	
Simple payback period	3.1	years
SIR	4.5	

This system is recommended for implementation with 0&M funds only in the event the large LCA system is installed.

Summary of ECO Projects

Three methods of funding were examined for all of the qualifying ECOs (SIR >= 1.0). ECIP funding is available for a package of ECOs with an SIR greater or equal to 1.0 and with a total investment cost of at least \$200,000. QRIP funding is available for a package of ECOs with a simple payback of 2 years or less and a total investment cost of not over \$100,000. PECIP funding is available for a package of ECOs with a simple payback of 4 years or less and a total investment cost of over \$3,000. QRIP and PECIP funding is based on simple payback and not on SIR as is ECIP. The eight temporary buildings which required the reevaluation of four select ECOs are included with the Temporary Buildings ECO packages.

ECIP Funding Projects:

ECIP projects for MFH units and Post Military Construction Army (MCA) 0&M buildings are funded separately, each under its own appropriation.

Seven ECO projects are recommended for ECIP funding in FY 1988. The projects were separated, for the most part, by expected economic life and by the type of retrofit work required (i.e. architectural, HVAC, electrical). Each project is summarized in a table below with its respective discrete portion (ECO) economic results shown by order of SIR. The investment costs include the construction costs plus a 5.5% SIOH. Each project was analyzed during Jan. 1985 through July, 1985.

MFH Buildings:

ECOs for 550 military family housing (MFH) buildings which qualify under the ECIP criteria were placed in two funding projects. Table ES.3 contains three discrete portion and total project results for 25 year life ECOs. Table ES.4 contains similar data for the single ECO having a 15 year life. The programmed FY 88 costs are \$2,517,000 and \$833,000 respectively.

TABLE ES.3

PROJECT SUMMARY - DISCRETE PORTION RESULTS

MFH PACKAGE #8 - ECIP PROJECT

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ELEC ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
3 12 1	11,088 0 26,702	12,412 0	50,430 29,382 121,450	295,996 285,156 1,574,573	2.81 2.11 1.65	8.4 5.6 12.3
TOTAL	37,790	12,412	201,262	2,155,725	1.87	10.2

TABLE ES.4

PROJECT SUMMARY - DISCRETE PORTION RESULTS

MFH PACKAGE #9 - ECIP PROJECT

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
9	14,847	67,530	713,506	1.58	7.5
TOTAL	14,847	67,530	713,506	1.58	7.5

Permanent Buildings:

Architectural ECOs for 83 permanent buildings qualify under the ECIP criteria. Table ES.5 contains four discrete portion results and the total project results for 25 year life ECOs. The programmed FY 88 cost is \$3,004,000.

Heating, ventilating and air conditioning (HVAC) ECOs for 103 permanent buildings qualify under the ECIP criteria. Table ES.6 contains six discrete portion and total project results for 15 year life ECOs. The programmed FY 88 cost is \$2,605,000.

Plant and lighting ECOs for 69 permanent buildings qualify under the ECIP criteria. Table ES.7 contains five discrete portion and total project results for 25 year life ECOs. The programmed FY 88 cost is \$1,846,000.

TABLE ES.5

PROJECT SUMMARY - DISCRETE PORTION RESULTS PERMANENT BUILDINGS PACKAGE #1 - ECIP PROJECT

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
3 2 4 1	16,916 26,892 1,182 11,224	73,729 117,905 5,163 50,799	372,477 1,311,067 74,379 814,938	2.40 1.92 1.48 1.33	20.5 10.5 13.7 15.2
TOTAL	56,214	247,596	2,572,861	1.79	12.8

TABLE ES.6

PROJECT SUMMARY - DISCRETE PORTION RESULTS

PERMANENT BUILDINGS PACKAGE #4 - ECIP PROJECT

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ELEC ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
24 31 14 16 23 19	242 20,662 60,192 663 212 51,047	121 249 2,303 10 0	1,371 90,154 264,843 2,846 964 227,033	1,981 179,616 681,197 11,037 6,414 1,350,853	8.42 6.13 5.23 3.61 2.11 1.89	1.5 2.3 2.6 3.7 6.3 7.9
TOTAL	133.018	2,683	587.212	2.231.098	3.27	4.3

TABLE ES.7

PROJECT SUMMARY - DISCRETE PORTION RESULTS

PERMANENT BUILDINGS PACKAGE #5 - ECIP PROJECT

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ELEC ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
9 35 12 34 32 13	25,816 0 0 17,583 16,654 0	12 2,166 5,256 0 0 917	112,572 5,127 12,442 79,972 75,747 2,171	61,821 13,011 54,775 651,352 774,752 24,995	38.80 4.17 2.97 2.49 2.07 1.08	0.5 3.0 4.0 8.5 9.9 10.9
TOTAL	60,053	8,351	288,032	1,580,705	3.71	5.4

Temporary Buildings:

Architectural, HVAC, plant and lighting ECOs for 33 temporary buildings qualify under the ECIP criteria. All of the ECOs were combined in one ECIP project due to the maximum 10 year expected life of the temporary buildings. Table ES.8 contains fourteen discrete portion and total project results for 10 year life buildings. The programmed FY 88 cost is \$944,000.

TABLE ES.8

PROJECT SUMMARY - DISCRETE PORTION RESULTS

TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - ECIP PROJECT

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ELEC ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
23	995	0	4,526	7,483	5.75	1.57
14	3,083	0	14,022	35,702	3.49	
19	6,944	0	31,583	118,813	2.24	4.17
9	99	16	488	2,189	2.08	4.25
3	776	0	3,529	12,552	1.96	5.02

TABLE ES.8 (Continued)

PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - ECIP PROJECT

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ELEC ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
12	0	233	552	2,557	1.79	4.04
21	169	0	769	3,391	1.72	5.65
27	1,444	0	6,568	35,714	1.48	6.40
1	5,615	0	25,539	174,556	1.39	6.48
31	359	0	1,633	11,379	1.36	6.61
2	1,946	0	8,856	63,890	1.31	6.84
34	10,091	0	45,897	335,029	1.20	7.62
5	17	0	77	723	1.01	8.86
4	147	0	669	6,305	1.01	8.94
TOTAL	31,685	249	144,702	810,284	1.58	5.81

QRIP Funding Projects:

The buildings involved in this analysis are all temporary and have a maximum economic life of 10 years. The QRIP funding criteria requires a maximum simple payback of 2 years or less and a maximum investment cost of \$100,000. The three QRIP projects have a total investment cost of \$202,615 and are divided by geographic area (north area, mid area, south area). The investment cost includes the construction cost plus a 5.5% SIOH. The QRIP projects were analyzed during Jan. 1985 through July, 1985 and are recommended for implementation during the next funding cycle.

Table ES.9 contains five discrete portion and total project results applicable to 23 temporary buildings. The project is composed of HVAC ECOs.

Table ES.10 contains three discrete portion and total project results applicable to 4 temporary buildings. The project is composed of HVAC ECOs.

Table ES.11 contains four discrete portion and total project results applicable to 15 temporary buildings. The project is composed of HVAC and electrical ECOs.

TABLE ES.9

PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - QRIP PROJECT NORTH AREA

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
14 31 34 23 9	4,488 4,121 6,232 124 110	20,413 18,744 28,345 564 500	12,258 14,479 47,330 1,069 2,690	15.70 12.20 5.60 5.02 1.76	0.57 0.74 1.62 1.80 5.10
TOTAL	15,075	68,566	77,826	8.28	1.09

TABLE ES.10

PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - QRIP PROJECT MID AREA

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED. INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
14 34 23	2,650 6,079 401	12,053 27,649 1,824	3,716 39,345 4,276	30.73 6.54 4.05	0.29 1.39 2.22
TOTAL	9.130	41,526	47,337	8.21	1.10

TABLE ES.11

PROJECT SUMMARY - DISCRETE PORTION RESULTS TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - QRIP PROJECT SOUTH AREA

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ELEC ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
14 19 34 12	2,830 1,451 9,849 0	0 0 0 45	12,872 6,600 44,786 107	11,029 7,426 69,699 515	10.91 8.16 6.00 1.93	0.83 1.12 1.51 3.74
TOTAL	14,130	45	64,374	88,669	6.77	1.34

PECIP Funding Projects:

The buildings involved in this analysis are all temporary and have a maximum economic life of 10 years. The PECIP funding criteria requires a maximum simple payback of 4 years or less and a minimum investment cost of \$3,000. The single PECIP project has a total construction cost of \$307,987. The investment cost includes the construction cost plus a 5.5% SIOH. The PECIP project was analyzed during Jan. 1985 through July, 1985 and is recommended for implementation during the next funding cycle.

Table ES.12 contains ten discrete portion and total project results applicable to 27 temporary buildings. The project encompasses architectural, HVAC and electrical ECOs.

PROJECT SUMMARY - DISCRETE PORTION RESULTS
TEMPORARY BUILDING PACKAGES #2, #3, #6, #7 - PECIP PROJECT

TABLE ES.12

ECO #	ANNUAL NAT GAS ENERGY SAVINGS (MBTU)	ANNUAL ELEC ENERGY SAVINGS (MBTU)	ANNUAL ENERGY COST SAVINGS (\$)	ESTIMATED INVESTMENT COST (\$) (1/85)	SIR	SIMPLE PAYBACK (YRS)
14	7,920	0	36,023	30,003	11.29	0.80
3	75	0	400	481	6.03	1.54
9	208	0	946	2,689	7.06	2.69
12	0	152	360	1,173	2.56	2.83
19	480	0	2,183	5,941	3.20	2.88
27	298	0	1,355	4,584	2.81	3.21
23	651	0	2,961	10,690	2.63	3.42
34	15,021	U	68,320	266,466	2.37	3.83
31	59	0	268	1,626	1.57	5.74
5	32	0	86	1,273	1.08	8.29
TOTAL	24,744	152	112,902	324,926	3.23	2.81

Project Documentation

The required project documentation for each of the projects described above has been completed and submitted.

EMCS EXECUTIVE SUMMARY

Objective

The objectives of the Energy Monitoring and Control System (EMCS) study at Fort Carson are threefold:

- a) Determine the physical practicality of installing an EMCS that meets the Army requirements set forth in TM5-815-2 dated June 1983, and in CEGS-13947 dated September, 1984.
- b) Determine the cost effectiveness in accordance with current Energy Conservation Investment Program (ECIP) criteria.
- c) Define a Low Cost Alternative (LCA) to the EMCS and determine its cost effectiveness.

Authority and Scope

The contractual authority for this specific study is Contract No. DACA45-84-C-0125. 179 buildings are designated in the Scope of Work to be included in the study. Eight buildings are either not in use or unconditioned. The study encompasses 171 buildings: 161 0 & M buildings and 10 reimbursable utilities buildings. Each group is studied for the application of an EMCS and a Low Cost Alternative system.

General Approach

The previous EMCS study accomplished by Burns & McDonnell in 1980 was reviewed for content and method of approach. Each of the 179 buildings designated for this study was inspected to validate data on as built drawings and to acquire functional use and operation data required for the analyses. Local loop controls and actuators were surveyed to determine 0 & M repair costs. Each mechanical/electrical system in each building was surveyed to determine the potential application of the various EMCS control and monitor functions.

The potential energy savings for the various EMCS functions were calculated using the approved method set forth by Boyd in "Standardized EMCS Energy Calculations", 1982. Certain energy parameters in the Newcomb & Boyd method must be determined, which vary according to building shell characteristics and the type of mechanical system. The 171 buildings were divided into 13 groups according to building construction features and mechanical/electrical system ities. A primary building was designated for each group, in detail using computer simulation to accurately studied calculate the energy parameters required for the EMCS energy savings calculations. The algorithms for the calculations have programmed (Facilities Automated Controls Evaluation,

(FACE)), and each building was evaluated for energy savings by EMCS function on each mechanical/electrical system. The energy savings for each system in each of the 171 buildings were calculated using the FACE program. Special attention was given to ensure realistic results. Maximum savings are on the order of 25% to 50% depending on the existing conditions in each building. Overall, the calculated energy savings should be somewhat conservative.

The economic analysis was made by first laying out the architecture for a large system:

- -Master Control Room (MCR) located in Building 1364.
- -Location of Data Transmission Media (DTM) trunk lines, slave lines, and line drivers.
- -Location of FIDs and MUXs by building.
- -Listing of the required sensors and controls in the Data Environment (DE) of each building.

Figure ES-1 shows the EMCS schematic for the 128 qualifying buildings. Cost estimates for each building were developed with FID, MUX and local DTM costs prorated by building. Annual energy cost savings for electricity and natural gas and annual maintenance cost increases were calculated for each building. Finally the Savings to Investment Ratio (SIR) and simple payback in years were calculated for each building and are shown in Table ES.1.

The Low Cost Alternative (LCA) configuration is defined as the distributed control and data environment elements of the EMCS. This results in all the energy savings of the EMCS with the single exception of electrical demand limiting. The same procedures for energy savings calculations, system layout and costing, and economic evaluation were followed for the LSA as for the EMCS. The LCA schematic and building report summary are shown in Figure ES-2 and Table ES.3.

A study of connecting the 10 reimbursable utilities buildings to the EMCS was made. The system schematic and building summary report are shown in Figure ES-3 and Table ES.3 respectively.

A study of implementing an LCA for the reimbursable utilities was made. The system schematic and building summary report are shown in Figure ES-4 and Table ES-4 respectively.


EMCS Results for the 0 & M Buildings

128 buildings qualify under the ECIP criteria and are shown in Figure ES-1. The project is recommended for the FY88 ECIP program, and the project development brochure and DD1391 have been completed and delivered with this report. The main project features are summarized below.

```
No. of Buildings
                                         128
                                     69,700 ft.
Length of buried cable
                                          43
No. of line drivers
                                          2
No. of modems
No. of FIDs
                                          35
No. of MUX panels
                                          93
No. of DE points
                                      5.739
                              (MBTU)
                                           37,538
Annual electrical savings
                                           86,976
                               ($)
Annual natural gas savings (MBTU)
                                          248,002
                               ($)
                                        1,064,069
                                           60,882
Annual maintenance cost
                                          6,918
Annual electrical demand savings
Net annual cost savings
Total EMCS investment cost
                                      $1,097,081
                                      $3,879,384
Simple payback period $3,879,384/$1,097,081 = 3.5  years
SIR = 9.42 \times 86,976 + 13.36 \times 1,064,069 - 9.11 \times 53,964
                           3,892,962
```

SIR = 3.7

The performance of the EMCS depends in a major way on the working condition of the local loop control elements. The repair and maintenance of these controls is an ongoing job that must be completed for any system to function properly. Each building was surveyed for broken or damaged controls and actuators to provide a reasonable and probable cost of repair, calibration and adjustment on the EMCS buildings. The estimated repair work cost is established to be \$246,671 and should be included in the 0&M budget for FY 88.



BLD6 E/C RATIC	460644	LETLE 99	- 4- 4- 4	4 Chana	@ @ tu tu tu m m m tu tu n	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
BLDG SIMPLE PAYBACK						, , , , , , , , , , , , , , , , , , ,
BLDG ECON SIR		21 - 5 8 8 8 8 8			2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	
TOTAL BLDG COST	679 533 936 936 901 822	R - 50 0 0 4 8 1	331433	9478	44 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4	15502 20047 10477 17747 17747 18745 18745 24290 23024 12955 17852
FID/ MUX COST	251.0 794.0 397.0 251.0 854.0	794.0 388.0 1117.0 854.0 319.0 319.0	•117.0 •319.0 •794.0 •319.0 •251.0 •117.0	• 574 • 0 • 574 • 0 • 931 • 0 • 388 • 0 • 588 • 0	931-0 931-0 9251-0 9854-0 9397-0 117-0	4.574.00 1.865.00 4.586.00 4.588.00 4.858.00 4.858.00 5.519.00 5.319.00 5.319.00
DATA TRANSMISSION COST	.450.0 .450.0 .750.0 718.0		05.0 04.0 37.0 00.0 95.0	,725.0 ,530.0 ,766.0 ,916.0 ,150.0	150.0 341.0 725.0 750.0 868.0 805.0	
TOTAL DEVICE COST	09 08 08 21 93 93	00000000000000000000000000000000000000	0 5 3 4 6 5 5 6 6 1 6 5 5 6 1 6 5 1 6 1 6 1 6 1	80 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		10 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
NET DOLLARS SAVED	8 23 4 9 0 0 2 1 5 0 0 0 1 1 1 2 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4	10004448	7 + 9 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	108 108 108 108 108 108 108 108 108 108	222222222222222222222222222222222222222	7,710 9,010 7,710 7,779 7,779 7,779 1,770 9,887 8,861 8,861 8,861 8,861
ANNUAL MAINT COST	1,340 1,667 718 745 801	000000000000000000000000000000000000000	6.00 6.00 6.00 6.00 6.00 6.00 6.00 6.00	~~ & m m a ·	114476567	830 1,002 830 887 888 1,824 1,214 1,151 1,151 1,151 1,151
N GAS SAVED MBTU	100	000000000000000000000000000000000000000	8080088 8080088	44 L 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	20000000000000000000000000000000000000	1,6538 1,6538 2,004 1,791 1,791 1,791 1,791 1,791 1,192 1,192 1,192
ELECT SAVED MBTU	+ ~ ~ ~ 10 4		~ # # # # \\	80 - 10 - 10 - 10 - 10 - 10 - 10 - 10 -	130 43333333	\$
DEMAND SAVED KH			16 25 7 7 7 14 16	128 21 53 54	211 2112 88 88 1111 126 136 136	3 1 1 3 3 4 4 5 5 5 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6
BLDG NO ****	B D D D D D D D	5 5 4 4 5 E 5 E	0 4 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9	100000H	139202021	2458 2558 2058 2058 2158 1219 2258 1532 811 6220

oc. #																																							
BLDG SIMPLE PAYBACK	2.7							•	•	• •			•	•			•	•	•	•	• •	9			4.9	•			•	9.9	•	• •	•	•	•	•	•	•	9•9
BLDG ECON SIR	50 10 11 11 11 11 11 11 11 11 11 11 11 11		•		•	4 4		•						•			•	•		•				•		•			•	•	•	• •		•	•	•	•	•	2 %
TOTAL BLDG COST	23504 39934	923 257	16 87	668	654	985 996	032	032	032	371	146	427	406	759	7 t t	995	519	285	021	222	7 7 0	9 4 0	599	337	337	313	986	208	364	385	1/c	40.0	364	364	385	385	372	372	23728
FID/ MUX COST	9.1	•794•0 •588•0	.117.0	.251.0	.854.0	0.597.0 0.397.0	•574•0	•574.0	0.470	54.0	691.0	.319.0	•574•0	9457.0	854.0	.251.0	. 194.0	. 194.0	9588.0	0 6 7 6 6	397.0	.588.0	.794.0	•574•0	•574•0	20 G	.574.0	.117.0	•854•0	•854•0	9834 · U	319.0	.854.0	.854.0	.854.0	•854•0	•574•0	•388•0	4.388.00 4.854.00
DATA TRANSMISSION COST	1,725.00	•006 •0 •725 •0	.840.0	.725.0	62.0	34.0	.840.0	40.0	9840.0	862.0	12.0	958.0	95.0	0 0 0	0.0014	,737.0	.012.0	25.0	9875.0	9 2 9	0.000	0.00	•725.0	805.0	02.0	0 • 99	.530.0	55.0	190.0	0.90	9 2 4 4 5	58.0	90.0	90.0	0.900.	•006•0	50.0	9341.0	,341.0 934.0
T0TAL DEVICE C0ST		43	3.91	1,02	0,83	63	3,91	3,91	3,91	7.99	8,76	4664	99	4 4 1 5	7.63	96.6	0,39	8,33	1 , 74	7 0 0	7.99	0,65	1,47	4.99	7,99	7 0	2,76	9.01	7 • 99	7 + 99	7.99	7.99	7,99	7.99	7,99	4664	7,99	7,999	96
NET DOLLARS SAVED	8,837	3,34 7,81	59	50	0.0	23	42	42	42	1	0.1	16	117	ສຸ	1 5	68	• 59	17	33	7 2	7	53	•62	• 62	62	6 to 2	99	• 36	•61	9	9 4 6	58	191	61	09	094	•	9 6	3,609
ANNUAL MAINT COST	1,997	• 12	1,708	95	CU I	9	51	-	+51 7.	→ ∝	57	21	\$20	7 œ	7 6	9	16	194	• 01	70		1 4	19	116	116	1 1 2	4	• 10	• 18	419	919	21	. 18	• 18	• 19	•19	• 18	• 18	1,186
N GAS SAVED MBTU	2+004 3+591	000	73	•27	25	36 36	+24	•24	200	ת ת	77	NO.	994	21	4 1 5		8 0	N E	9.7	0 0	0.7	. ~	7.1	• 0 7	• 07	70	29	• 01	• 0 7	+ 0 +		• 07	• 07	• 07	• 07	104	+07	70.	~ ~
ELECT SAVED MBTU	132	204	50 0	4	9 1	732	6	6	6	0 10	3	m	₩,	- F	0 10	œ	7	507	-	0 0 0	96	349	88	96	96	9.6	510	9	96	96	9 70	96	96	96	96	96	96	96	96
DEMAND SAVED KW	19 CC I	12	7	42	16	2 2	14	14	4 4	· ·	0	9	9	2	1 6	19	10	2.2	26	9 4	0 40	27	11	9	9	a 42	19	6 0	9	9 (ם ע	9	9	9	9	9	9 '	• •	9 9
BLDG NO	1012	15	- 4	22	16	90 1	99	99	99	מנו	30	95	55	9 8	מ מ	15	52	22	4 1	2 L	7	010	01	95	95	פיני	35	36	0.2	<u> </u>		95	05	05	0 7	0.7	07	ני	25

BLDG SIMPLE PAYBACK		- B C B B B B B B B B B B B B B B B B B			· • • • • • • • • •	2 2 2 2 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3
BLDG ECON SIR		2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2				
TOTAL BLDG COST	8408 8408 8443 8443 843	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2		233 233 349 349 918 750 750	500 500 500 500 500 500 500 500 500 500	25775 25967 19016 51246 16606 21950 18956 10257 19185
FID/ MUX COST		8854 8319 8319 8319 8319 8574 8574	854 0 854 0 854 0 8574 0 8574 0	148.0 1148.0 117.0 397.0 854.0 574.0	397.0 148.0 148.0 2551.0 257.0 558.0 558.0 558.0 319.0	
DATA TRANSMISSION COST	934 495 862 862 962 962	868.0 150.0 150.0 150.0 150.0	9559 9559 9559 9559 9559 9559	012.0 012.0 150.0 084.0 084.0 530.0	221.0 012.0 012.0 150.0 025.0 025.0 084.0	110 110 110 110 110 110 110 110 110 110
TOTAL DEVICE COST	6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6	7 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4		6,17 6,17 1,23 1,23 1,23 1,23 1,23 1,23 1,23 1,23	3 4 4 4 10 10 10 10 10 10 10 10 10 10 10 10 10	
NET DOLLARS SAVED	000000000000000000000000000000000000000			86 986 986 71 17 112 112	77.00 9.00 9.00 9.00 9.00 9.00 9.00 9.00	4000000000000000000000000000000000000
ANNUAL MAINT COST	8007770	1000000 000000000000000000000000000000	222222	1175676	27 7 2 3 4 4 2 4 4 5 4 4 5 4 4 6 4 6 4 6 4 6 5 7 5 7 5 7 5 7 5 7 5 7 5 7 5 7 5 7 5	1,289 1,298 1,298 2,562 1,097 1,097 1,097 1,097 1,097 1,097
N GAS SAVED MBTU		00000000		4014166	B 4 4 7 E B 11 11 11	713 713 428 843 343 470 297 215 215 215 215
ELECT SAVED MBTU *****						50 264 1,230 133 217 217 75 75
DEMAND SAVED KW	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	. ന ന ന ന න 😄 ထ a	စေထာင္းထားထားတာ		1 177 2 7 7 0 0 0	0 0 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
* * * * * * * * * * * * * * * * * * *	244440	010000000000000000000000000000000000000	1	0045455	00000000000000000000000000000000000000	1670 1660 1048 7300 7500 1852 1854 2055 2056 2354

	BCU E/ RATI	* * * *	r\s	8	~	24	~	N	CI	C4	-	2	2	(V	(1)	-		
	SIMPLE PAYBACK	*****	19.9	22.4	19.7	21.0	21.0	21.0	21.0	26.3	31.0	47.0	45.0	46.3	47.7	548.2		
	ECON SIR	*****	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	9.0	0.5	0.5	0.5	0.4	0.2		
	BLDG	*****	10539												22393	13706	## ## ## ## ## ## ##	3360583
	MUX	****	4.574.00	4.574.00	4.574.00	4.574.00	4.574.00	4.388.00	4.388.00	6+251+00	5,319,00	1,862,00	1.862.00	1,862,00	1,862,00	4.854.00	11 11 11 11 11 11 11 11 11 11	655,355.00
	TRANSMISSION COST	· · · · · · · · · · · · · · · · · · ·	862.00	1,495.00	805.00	1,150,00	1,150,00	1+341+00	1,341,00	1,725,00	1,150.00	2,204.00	1,916.00	2,108.00	2,300,00	5.750.00		273,510.00
	DEVICE	********	5,103	5,103	5,103	5,103	5,103	5,103	5,103	11,023	11,383	18,231	18,231	18,231	18,231	3,102	11 11 11 11 11 11 11 11 11 11	2,431,718
	DOLLARS SAVED	*****	530	498	533	516	516	515	515	722	576	474	489	419	469	25	11 66 11 11 11 11 11	1056440
- 4	MAINT	*****	527	559	524	541	541	545	542	950	893	1,115	1,100	1 + 1 1 0	1,120	685	## ## ## ## ## ##	168019
	SAVED MBTU	*****	215	215	215	215	215	215	215	315	323	317	317	317	317	131	86 83 88 88 88 88 88 88	261,604
	SAVED MBTU	***	75	75	75	75	75	7.5	75	119	0	124	124	124	124	57	#1 #2 #2 #2 #2 #3	41,652
	SAVED KW	* * *	ю	М	Ю	m	ĸ	M	ю	6 0	0	9	9	9	9	4	## ## ## ## ## ##	2,157
+	BLDG NO	* * * *	2456	2556	1955	2075	2076	2155	2156	1001	6230	1362	1368	1668	1662	1450		

LCA Results for the 0 & M_Buildings

126 buildings qualify under the ECIP criteria for a Low Cost Alternative system. The schematic is shown in Figure ES-2. This system is not recommended for ECIP funding. While it provides almost the same energy savings as the EMCS, it requires the same maintenance effort for the FIDs, MUXs, and the 5712 points in the Data Environment as does the EMCS. Also, it does not provide the many maintenance advantages and system reporting capabilities that the EMCS does. The system features and performance are summarized below.

No. of buildings	126	
Length of buried cable	27,110	ft.
No. of line drivers	0	
No. of modems	0	
No. of FIDs	38	
No. of MUX panels	88	
No. of DE points	5,712	
Annual electrical savings	37,434	MBTU/\$88,614
Annual natural gas savings	247,237	MBTU/\$1,059,374
Annual maintenance cost	\$ 148,433	
Net annual savings	\$ 851,103	
Total LCA investment cost	\$2,968,651	
Simple payback period	3.1	years
SIR	4.6	

Reimbursable Utilities Buildings EMCS Results

This system connects to the large EMCS described above. It is feasible only if the large EMCS is implemented. Although no energy cost savings may be claimed under the ECIP program, certainly the avoided energy costs of such a system should be considered in making the decision whether or not to implement it. Figure ES-3 presents the schematic. Overall features for the 10 buildings are:

No. of FIDs	2	
No. of MUX panels	8	
Length of DTM lines	2,940	ft.
No. of DE points	568	
Annual electrical energy savings	3,337	MBTU/\$7,067
Annual natural gas savings	14,306	MBTU/\$60,908
Annual maintenance cost	\$ 8,997	
Net annual avoided costs	\$58,978	
Total investment cost (8/85)	\$179,945	
Simple payback period	3.2	years
SIR	4.4	•

This system is recommended for connection to the EMCS for the $120\,$ 0 & M buildings.

815 815 18 94 - 814 1014	FIO#18 1665 21084 - 1661 - 1665 - 1666 - 1666	FIO#27 1160 Pts 1460 Pts - 2150 - 2150 - 2150	10 2 6 80 2 6 80 2 6		
F10#8 1013 124 Rt. 1011	80142 80142 192 845 19152	FIC#26 2152 198 R3 -2153 -2153 -2154	FID#35 9612 27 Ph	6CHEMATIC	
F10#7 1118 152 P35 1117	FID#UP 60100 901000	FID#25 2077 152 R3 - 2074 - 2078 - 2140	F10#34 12957 12952 12954 12954 12954	LCA FID/MUX 4	がた しょん
FIOK 1218 12785 1217	RIO#15 8620 194 月 8030	FIO#24 2073 100 Pb - 2070 - 2071 - 2072	F10433 2461 146 A3 - 2550 - 2550		51.
F1045 1219 128件 1220	FICH 14 1360 117795 1361 1364 1365	HOM23 12851 12851 12851 12851	F10#32 2468 136 PA 2452 72452 72453		
F1044 1225 122 Rt	FID#13 1352 20183 1352 1354 1367 1569	FID#22 2000 2000 2000 - 2005 - 2053 - 2053	F10#31 2454 1458 17458 17458 17458		
FIDH3 1430 178 PL 1500 1500	FIDH12 112/R2 1041 - 1042 - 1046	12#2H 12#2H 12:00:1 13:00:1 13:00:1	FID#32 1251 134 F5 1250 - 2350 - 2351 - 2351		
FID#2 1526 183 R3 - 1511 - 1519 - 1532	HOH II 135821 1030 1030 1040 1043	FID#26 1955 156 A5 -1951 -1952	H0420 L687 - 2253 - 2254 - 2256		
HD#1 7301 13672 6220 7302	1.020 1.020 1.021 1.021 1.021	2.10 2.42 2.42 2.42 2.42 2.42 2.42 2.42 2.4	2016 2160 2100 200 7.250 7.251 7.251		

П

\$UO*	6	m ≃) (2)	ę	ت	4.	്) ပြ	` -		-	 .	n) 1) (†	T)	4	٠,	3 (ה מ		-4	ו מו	n u	ເດ	ťλ	យា	0 (n c) ()	5	- '	n c	J VQ	(M)	3	6	8	Q	ď١	σ.	2 (ر ان ان ان
BLDC E/C RATIC	9.6	6.7	4 6	36	3.1	<u>ي</u>	7 0	י כש	20	C/I	C) (210	1 111	17	18	17	7 7	1 7	16	17	±0 (n -	1 1	4		MP) (MPH V	4 10	,	2			4) (**) ~*(===	12	Ů,	J.	1 (7 .	-, - -
BLDG SIMPLE PAYBACK ******						-				•				•	•	•					•			•	•	•				•				•	-	•	•		•	•	2 K
BLDG ECON SIR	ا		, w)	æ	• 9	.	• •	- 0		.		• c	. 6			•	•							•	•	•	• '	• •	•		•				•			•	•	•	0 0 0
TOTAL BLDG COST	9.0	316	295	0	045	277	7 + 0	126	126	126	126	140	659	611	255	240	7 7 10 10 10 10 10 10 10 10 10 10 10 10 10	284	4 0 5	361	465	ລ ຜິດ	482	482	407	605	4 0 0 0	465	594	615	600 446	7.06	752	743	801	782	691	229	229	N (22293
FID/ MUX COST	• 588 • 0	വ • •	.588.0	,251.0	457.0	798.2	0 · 0 0 0 × ·	55.0	.965.0	1962.0	1965.0	\$ • Q Q Q • *	1588.0	.588.0	9588.0	38.5	000 000 000 000 000	98.5	15.8	558.8	88.3	6.088. 6.088.	1.388.0	88.0	558.8	24 e 12	258.8 457.8	397.0	,155,5	• 015 • 8	0.0014	•11. •015.8	,315.8	*155.5	.015.8	\$ 588 · 6	155.5	.574.6	9.974.6	45/4•6	4.574.60
DATA TRANSMISSION MCR COST	16.5	9 . 6	51.5	16.1	147.9	58°E	0.00	37.5	,337.5	,337.5	•337 •5	1346.E	137.1	44.3	353.6	•258 • 2	9683.2	•617.6	9588.8	.028.2	*818 • 8	2 . x . x	292.3	292.3	88.2	• 247 • 3	0.1170	.818.8	.258.2	603.2	101/06	128.2	.488.2	+258.2	.977.9	277.8	,373.1	,258.7	,258.7	1.8524	1,258.75
T01AL DEVICE C0ST	60	7,08 5,41	21	93	6 4 8 5	50	0 K	5,95	95	95	995	ָ האַ	0,87	0.38	•61	0,53	4 5 5 5	0 10	8 + 4 4	• 02	444	444	45.0	8 9 9 4	2.02	\$ 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	これのこと	443	0,53	0.553	0 0 0 0 U	2.02	0.5	2,12	2,02	1,95	1,38	6,46	6 9 4 6	0.40	16,460
NET DOLLARS SAVED ******	8 0 0 2	26	2,81	6.01	2,73	4 4 11 7	o (7 r () • •	8,48	448	\$ 48	2. d	7 7 4	1,09	• 19	9 8 9	သ (0 r	7 B	5.6	3	27	- W	99.9	5.	7.86	₩	ວ ແ ອ ເ	2 4 (T)	96	196	107	7.1	9	969	• 66	39	10 10 10 10 10 10 10 10 10 10 10 10 10 1	11	77.		8,773
ANNUAL MAINT COST		• ೧೩ ೮೮	-3*	F.)	Cu :	0 0	3 40) W	9	· e	0 0	- 1	· M		CVI	Cd I	റാ	O 4	(2)	(3)	:00 1	00	+74	す	7.0	ာ (ソト	- 10	3	□ •	→ ¬	ວ ແ	-	7	1	3	3	, 11	• 1 1	ન . ન . ક્ર	1,115
N GAS SAVED MBTU *****	• 76	പത ••• നേഗ	• 14	មិន	e 7 e	() () () ()	0 <u>-</u>	(A)	3.02	(3) (3)	O4 0 □ 0 • 0	0 C	98	• 4 Ū	5 ≥ •	00 °	. 0 €	 	0.0	• 79	ت ت ا	55. 67.	446	440	62.	4 4 6	• • • • • • •	4 43	\$ 12.3 \$	# (2.3)	7) e 20 d ●	67.	*79	62	61	4 S.4	\$ 62	() ()	(D)	n : ⊃ : •	2,004
ELECT SAVED MOTU	J 1	> 4.00 - €	N7	50	4 ,	-4 :	S es	+ 3	4	÷ .	3 3	r 4	· 10	_q md	+	- 1	~ 4	- 1	4	0	S	いなない	10	0	M) :	ツ ("	· ~	4 (Si	1	r 1	* 4	r (()	1.00	N)	NO.	3		M) .	·) :		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
DEMAND SAVED KW	0.	a. m	⊅	÷.	a ·	. 3 -	* 1) ()	Ö	.D. 6	ಶ	י) כ	(0)	C	(77)	3 4	· 6	5 (3	13	τ3	9	ta en	r 7 Di	C)		20 1	מי כי) ()	٠.	5	7	o ku	. co	.5	70	. TO 1	(°°	<i>a</i> .	73	יל	. +3
# # # # # # # # # # # # # # # # # # #	100	3000 1446	(N)	9	i m	Ω - ∞ ::	4 (0)	66	36	36	တ် ∹ တောင်	1 4	30	65	4	υ. υ.	១១ ÷ជ	0.0	9	5	30.00	20	5	21	15	7 5	- K	3 (2)	50	4 U	ט ה	1 (3)		25	10	11	22	10		4 -	1012

11.06 E7C PATIO	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	# # # # # # # # # # # # # # # # # # #	83 77 77 70 70 70 70	8 5 6 5 3 E	もてらせらら ゆりてめなす	មាមមាមមាលស្ខៈ មាលស្សាស្តេស្មស្ត) មិលិស្ធ444ជ្រះ ស្រួមមុ ពេល្យ ១៤៤ ស្រួស្ស ១០១០១១
SI 36 26 SI 36 P.L.F PAYLACK *****							
PLDG ECON SIR ***							
TOTAL BLDG COST	904	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	925 418 348 357 384 384	3338 312 778	481 431 379 564 974	311 3211 3211 3211 3324 3324 3324	200 200 200 200 200 200 200 200 200 200
FID/ MUX COST	.574.6 .854.0 .588.0 .554.0		* 465.0 931.3 455.5 9115.8 9388.0	386-8 315-8 255-2 155-5	794.0 5.797.0 5.55.5 117.6 5.588.0		4 4 110 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6
DATA THANSMISSION MCR COST	258.7 232.8 151.5 099.3	653.2 6753.2 676.3 870.0 870.0	370 0 330 4 330 4 560 4 339 2	662 6 100 4 494 7 330 4	625 1 250 9 402 0 201 0 400 6	10000000000000000000000000000000000000	1,330 1,330 1,3330 2,049 2,049 2,049 2,049 1,560 1,560 1,330 1,330 1,330 1,330 1,330 1,330 1,330 1,330 1,330 1,330
T0TAL DEVICE C0ST	64 0 0 4 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0.000 0.000 0.000 0.000 0.000 0.000 0.000	0 4 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	3,75 7,63 7,63 7,63	0.33 8.33 8.76 0.65 0.65	00000000000000000000000000000000000000	17, 9999 17, 9999 17, 9999 17, 9999 17, 9999 17, 9999 17, 9999 17, 9999
NET DOLLAKS SAVED ********	77 61 61 41 75	0 5 T 3 7 3 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	4 0 4 0 4 0 4 0 4 0 4 0 4 0 4 0 4 0 4 0	3000	20 d d d d d d d d d d d d d d d d d d d	0 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	>>> \q
ANNUAL MAINT COST	- O O O F	20 at at at the	446 714 714 714 919	9 M 9 M 30 :	74 • 55 71 • 68 • 48 • 48	* * * * * * * * * * * * * * * * * * *	
0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		りかりとはらうことにつ	400040	* * * * * * * * * * * * * * * * * * *	2017 100 100 100 100 100 100 100 100 100		
# # # # # # # # # # # # # # # # # # #	- のめいすじ	3 40 7 50 5 7	୍ରଧ୍ୟ ଅଷ୍ଟ ଅ ଓ ଧାର୍ଶ ଅଟେଶ ଅଟି ସାଧାରଣ ସ	37 37 30 30 P-1	こうり ひょう	10 00 00 00 00 00 00 00 00 00 00 00 00 0	. မေလာမ္းမရိုင္ ရိုင္း () . နာလ ၁ က က လ က လ လ လ လ လ လ
	.e (e (a) (e (e (e) (e) (e) (e) (e) (e) (e) (e)		(3 m (3 m m)	ଗଠପାଇନେ:		υΣαασσαααα.	s a kangaran ang manangan garanggan garanggan garanggan garanggan garanggan garanggan garanggan garanggan gara
* * * * * * * * * * * * * * * * * * *	- 00 - 00 -	4 3 4 4 4 4 4	ាលល្យ ១១១១១១១៣	2003	6 14 15 15 15 15 15 15 15 15 15 15 15 15 15	aaaaaaaaaaaa	20000000000000000000000000000000000000

D6	4	ည ရ ရ	n c	ا ا ا	5 0) (I	ت د با د	2 4	64	49	44	46	44	5 4	† 4 † 4	44	44	41	41	4 -	t 4	44	44	47 4 10 10	n +	4 50	35	45 to	- n	32	32	32	67 F	2 6	(v (3.7	41	ر ا ا		N 0	1 C	, ,
BL RAT ***																			.0		0 12			-4 1	C 15		_	ရာ မ	· ~	. 01	01				. ~		10	×2 :	· ·	n ^	. ~	• 2
BLDG SIMPLE PAYBACK		בי בי		0 4	•		•	•			8•9												•	•	•		0	• о с		N	Š	٠. ن	ເປັດ	vς	ı N	(1)	4	9	'n.	•	ວິລ	; 4
BLDG ECON SIR												•	•	•					•								S.	പ -			•			• •		•	•	•	•	•	• •	•
TOTAL BLDG CUST		2 4 4 5 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6	240	460	ט ט א כ	369	9 6	384	384	384	345	453	436	400	4004	4 36	436	177	177	793	1 4 0 10 0 10	453	453	712	7 L C	398	398	11181	414	387	387	370	370	3 7 6	936	846	359	855	672	11 to 4	110	++0
FID/ MUX COST	i.	0 0 0 1 m	0.000 m			111111111111111111111111111111111111111	015.8	155.5	155.5	155.5	9.4154	836.8	965.0	0.765.eU	965	965.0	.965.0	155.5	155.5	457.0	0 • 0 0 0 ° *	386.8	.586.8	854 • 0	* 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	155.5	.155.5	3 2886 84		886.8	8.386.8	*965.0	.965.0	* 760 • E	* 255° 2	429 • 8	698.5	,255.2	194.0	10 to	8 - 21 5 - 8	
DATA TRANSMISSION MCR COST		40000	4.000.	40101	4 37 3	675.4	675.4	689.8	\$689°B	•689.8	+143.2	\$633.7	384.4	4004	384.4	384.4	.384.4	•445•3	4445.3	173.2	633.7	.633.7	,633.7	\$869.3	465.0	8 9 2 6 7 4	•430.8	1.590.46	*0.00 *6.06 *5.06	6.049.	9640.9	•391•6	*391.6	301106	447.8	.6699	•665.4	,418.9	841.4	62.0	4 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6	
TOTAL DEVICE COST COST	2	7 500	7.00	7.99	00.7	7.99	7.99	66	1,99	7,99	7,73	9,01	9 • 01	1040	10.6	9,01	9,01	6,17	6,17	4.30	10.	9,01	9,01	0,39	4 0 4	8 40	• 4 0	10 0	1.03	34	8,34	8,34	8 3 4	3 4 5 4 5 4 4 5 4 5 4 5 4 5 4 5 4 5 4 5	3.66	6936	8,23	2,88	3,09	5,8 ¢) /T	\$ (
NET DOLLARS SAVED		0 0	0 d	יני ער	7 1	7 6	1 10	5 8	58	58	164	443	22	N 0	70	2 1 2	22	89	8.9	33.9	1 2	21	21	10	0 0	400	946	1,128	• • ν τ ν τ	ים נחנ	9.95	98	დე ს ტ	* * * * * * * *	, ,	\$ 28	644	• 14	• ∵ •	* 3. 3. 3. 3. 3. 3. 3. 3. 3. 3. 3. 3. 3.	1 7	٠ ١
ANNUAL MAINT COST	,		7	C 3	G 0	3. c	2 00	3	• 19	• 19	67	\$25		17.	4 C L	21	+21	3 2 1	သည္။	20 c	1 C	22	.22	5	r r	• 0 0	5	555	מ מ) (H	119	• 1 e	20 0	α • •	96	CA	100	CVi	~) :	ಶ ೧೧೯ 1	2 .3	
N GAS SAVED MBTU ******	ç	2 0) () ()	- 1	- 1	2 0	0	. ~	104	204	57	104	~ .	ન હ 3 લ •	7 C	1 (1)	• 01	3	· O	ς Σ	4 ~	0.1	.01	00 4	+ r	- 4	4	341	7 -	4 +4			-4 *	-4	4 3	:73	4	D.	r 1	٠,		4 1
ELECT SAVED MBTU *****	ì	9 (J	D 4 N d	0 V	0 V	0 7	. 2. D : 3.	9.0	96	96	23	ന ഗ	0.4	dr - €	3 4 4 4) D	64	54	40	₩.	0 1	9 9	9	143	5 C	D 147	(4)	135	- 1-	- ເລ + ຜາ	96	 ()	നാ (ഹോ (ລິດ) 4) E.	: 0	:1)	+	Y) .	717	. F	3 6
DEMAND SAVED KW			σ.	n d	0.0	চ 🟗) (2	s 109	co	ē		ra (ကင်	a 6	D (, ,	o	co	.7	ு . -	3 0	ောင်း	m	ro s	a c	o (*;	ထ	erti i	5 73	23	co	m	em e	э c	ייי כ	n		c	.m -	rs v	3 -5	:
* * * 90	,	n :	r c	5 -	→ c	V M	3	0	-	52	_	Q.	1363	η,	0.00	1	54)4	2	20 1	2 4		1	+ (r Na	9 M	īΟ.	<u> </u>	a co	מי	6	c	.		3 (3	. aj	.5	4		CV 11	n 42	1 0

	M GAS ANNHAL	ANNIA	Δ .	14		TOTAL	DATA	1013	TOTAL	מומ	20 Id	20
SAVED SAVED	SAVED MAINT	MAINT	1 <u>-</u>	DOLLARS		DEVICE	TRANSMISSION	X D W	9018	ECON	S	2/3
	METU COST	COST	ST	SAVED		1800	MCR COST	COST	COST	SIR	a_	RATIO
水柱 不不不存在的现在 医骨骨骨骨骨骨 医骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨骨	化化苯基甲基苯甲基甲基甲基甲基甲基甲基甲基甲基甲基甲基甲基甲基甲基甲基甲基甲基甲	***	***	黄素 法有法律的法律	*	***	****	***	****	***	****	* * * *
215 534	215 534	534	34	513		5,103	1,567,18	4+315+80	10686	S • 0	20.8	. 27
534	215 534	534	34	513		5,103	1,567,18	4.315.80	10686	8.0	20.8	27
5 542	215 542	5 542	42	505		5,103	1,581,55	4,155,50	10840	8.0	21.5	27
	215 524	15 524		523		5,103	1,222,18	4,155,50	10481	3 • O	20.0	28
215 553	215 553	15 553	53	464		5,103	1,940,93	4,315,80	11060	æ • a	22.4	26
ଓ ଓଟନ୍ତ	215 555	ଓ ଓଟନ୍ତ	53	464		5,103	1,946,93	4+)15+80	11060	8 • J		26
5	215 529	5 529	29	518		5,103	1,452,18	4,115,80	10571	8 • 0		27
	215 529	5 529	29	518		5,103	1,452,18	4,315,80	10571	0.8		27
5 846	5 846	5 846	46	623		11,383	1,373,14	4,155,50	16912	10.7		19
	24 317 1:009	600*1 2	600	565		18,231	1,449,43	508.00	20188	0.5		22
317 1+0	24 317 1+009	1,009	60	566		18,231	1,449,43	508.60	20188	G•0		22
4 317 1,182	4 317 1,182	7 1,182	82	387		16,231	1,449,43	3,965,00	23645	0.4		19
4 317 1+1	4 317 1,182	7 1,182		387		18,231	1,449,43	3,965,00	23645	0.4		19
o 57 131 510 186	7 131 510	1 510	10	186		3,102	841.45	6,251,00	10194	0.4	54.8	18
			11 11 11 11 11 11 11 11 11 11 11 11 11	11			11 11 11 11 11 11 11 11 11 11 11 11 11	11 11 11 11 11 11 11 11 11				
0 41,652 261,604 163923 1053224	52 261,604 163923	61,604 163923	3923	1053224		2,431,718	220,006,92	626,899.86	3278622			

Reimbursable Utilities Buildings LCA Results

This system is feasible providing that an EMCS or LCA is installed on the 0 & M buildings. The energy cost savings are actually avoided costs, and are provided for use in decision making. The schematic is shown in Figure ES-4. The features are summarized below:

3 No. of FIDs 6 No. of MUX panels Feet of DTM 1,440 ft. 568 No. of DE points 3,337 MBTU/\$6,036 Annual electrical energy savings 14,306 MBTU/\$60,908 Annual natural gas savings Annual maintenance cost \$ 8,694 \$58,250 Net annual avoided costs \$173,889 Total investment cost 3.1 years Simple payback period 4.5 SIR

This system is not recommended if an EMCS is installed on the 128 qualifying buildings. It is recommended if the LCA system is installed on the 126 qualifying buildings.




Table ES.3 EMCS Building Report Reimbursable Utilities Group

BLDG NO	DEMAND SAVED KW	ELECT SAVED MBTU	n gas Saved Mbtu ****	ANNUAL MAINT COST	NET DULLARS SAVED	TOTAL DEVICE COST	DATA TRANSMISSION MCR COST	FID/ MUX COST	TOTAL BLDG. COST	BLDG ECON SIR	BLDG SIMPLE PAYBACK	BLDG E/C RATIO
1510	136	1,132	5,719	1,646	25,196	23,507	3,163	6,251	32,920	13.3	1.3	208
1525	81	592	3,564	1,233	15,271	18,703	3,163	2,794	24,659	10.2	1.6	169
1230	60	826	1,754	1,228	7,918	19,156	1,955	3,457	24,568	7.5	3.1	105
1517	23	207	1,345	859	5,312	11,712	2,013	3,457	17,181	5.2	3.2	90
2355	7	168	745	513	2,980	4,502	2,300	3,457	10,259	4.0	3.4	89
1008	10	137	400	492	1,487	4,662	1,725	3,457	9,844	2.6	6.6	5 5
5940	6	144	306	411	1,175	4,220	54 6	3,457	8 ,22 3	2.1	7.0	5 5
1161	6	131	473	653	1,601	9,323	2 87	3,457	13,067	2.0	8.2	46
1851	4	83	342	544	1,071	7,146	2 87	3,457	10,890	1.7	10.2	39
1515	3	33	196	462	446	3,776	2,012	3,457	9,245	0.9	20.7	25
		====	====		====	======		===	=====			
	336	3,453	14,844	8,041	62,457	106,707	17 ,451	36, 701	160,856			

Table ES.4 Low Cost Alternative Building Report Reimbursable Utilities Group

BLDG NO	DEMAND SAVED KW	ELECT SAVED MBTU	n gas Saved Mbtu	ANNUAL MAINT COST	NET DOLLARS SAVED	TOTAL DEVICE COST	DATA TRANSMISSION MCR COST	FID/ MUX COST	TOTAL BLDG. COST	BLDG ECON SIR	BLDG SIMPLE PAYBACK	BLDG E/C RATIO
				*								
1510	0	1,132	5,719	1,455	24,919	23,507	0	5,588	29,095	14.1	1.2	235
1525	0	592	3,564	1,215	15,011	18,703	0	5,588	24,291	9.9	1.6	171
1230	0	826	1,754	1,228	7,712	19,156	1,956	3,457	24,568	7.1	3.2	105
1517	0	207	1,345	859	5,232	11,712	2,011	3,457	17,181	5.0	3.3	90
2355	0	168	745	504	2,965	4,502	0	5,588	10,090	4.0	3.4	90
1008	0	137	400	492	1,453	4,662	1,725	3,457	9,844	2.5	6.8	5 5
594 0	0	144	306	384	1,182	4,220	0	3,457	7,677	2.3	6.5	5 9
1161	0	131	473	653	1,580	9,323	288	3,457	13,067	2.0	8.3	46
1851	0	83	342	544	1,058	7,146	288	3,457	10,890	1.6	10.3	3 9
1515	0	33	196	462	436	3,776	2,011	3,457	9,245	8.0	21.2	25
		===	====									
	0	3,453	14,844	7,796	61,548	106,707	8 ,2 79	40,963	155,948			

FID39 1510*	FID 28 1856 1851*	FID10 1225 1230*	UILDINGS FIGURE E5-4
FID4 1519 1515*	FID18 1352 1161*	FID41 5940*	REMBURSABLE UMUTIES BUILDINGS LCA SCHEMATIC FIGURE
FID.15 10014 10008	FID40 1525*	FID34 2351 2355*	Rembur LCA 2

* DENOTES REIMBURSABLE UTILITIES BUILDINGS

ES.19